



ADDENDUM #2

C-STREET PARKING GARAGE LED RETROFIT

BID #13/14-004 – PWP# WA-2013-293

BIDS DUE NO LATER THAN: 1:45 PM ON AUGUST 15, 2013

PUBLIC BID OPENING: 2:00 PM ON AUGUST 15, 2013

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

Clarifications

- 1) Sheet E0.1, Light Fixture Schedule & E1.4:
For the Type L2 fixture (2) LED fixture heads shall be mounted on the existing poles. Provide (2) BetaLED ARE-EDG-4M-DA-100-D-UL-BZ-525-P-ML & XA-BRDSPK fixtures on each of (4) poles.
- 2) Sheet E0.1, Light Fixture Schedule and E2.1:
For the Type L4 fixture (2) LED fixture heads shall be mounted on the existing poles. Provide (2) BetaLED ARE-EDG-4M-DA-100-D-UL-SV-525-P-ML & XA-BRDSPK fixtures on each of (8) poles.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 2 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal (not later than 1:45 pm on August 15, 2013). Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X_____
Authorized Signature

August 12, 2013

Printed Name of Person Signing