



ADDENDUM #2
MARINA ROCK WALL AND STAIRWAY REPAIR
BID # 21/22-003 / PWP # WA-2022-033
BIDS DUE NO LATER THAN: 1:45 PM ON OCTOBER 20, 2021
PUBLIC BID OPENING: 2:00 PM ON OCTOBER 20, 2021

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

A) **COVID-19 Precautions** – Due to the City’s response to the COVID-19 virus and associated reduction in staff, in-person staff availability is limited. Bidders wishing to physically deliver their bids on the bid due date shall note that the Purchasing Office will receive bids in the lobby of City Hall beginning at 1PM on October 20th. Bids are due no later than 1:45PM. Bids may also be delivered to the Purchasing Department physical dropbox/mailbox, also located in the lobby of City Hall.

B) RFI question responses:

- a. Is there a specific class of rock that is stipulated? Or just Basalt rock that closely scales to the configuration on page C3.0?
 - i. **Answer:** See detail on sheet C3.0. It is noted below the title of the detail that: “(SEPARATE PERMIT; CONTRACTOR TO PROVIDE STRUCTURAL ENGINEERING CALCS.). The contractor is responsible for obtaining a permit for the rockery wall, which includes providing the structural engineering calculations required to obtain the permit. The intent is for the rock to closely match the aesthetic look and type of the existing rockery wall, while providing safe environmentally stable rocks, that maintain minimal degradation through weathering and environmental conditions after installation.
- b. Is the stair system a prefabricated unit or custom? If pre-fab please list company, model, color, etc.
 - i. **Answer:** The stair system shall be custom per the structural plan sheets S2.1, S5.1, and any other pertinent items noted in the bid documents and plans. The low bidder shall supply shop drawings to the City for approval by the engineer.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #2, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 2 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X_____
Authorized Signature

October 15, 2021

Printed Name of Person Signing