

4TH STREET SEWER & STORM DRAIN PROJECT BID # 22/23-014 / PWP # WA-2023-103

BIDS DUE NO LATER THAN: 1:45 PM ON DECEMBER 15, 2022 PUBLIC BID OPENING: 2:00 PM ON DECEMBER 15, 2022

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

A) **Bid Document Delivery** — Due to hybrid schedules and staff reductions, in-person staff availability is limited. Bidders wishing to physically deliver their bids on the bid due date shall note that the Purchasing Office will receive bids in the lobby of City Hall beginning at 1PM on December 15th. Bids are due no later than 1:45PM. Bids may also be delivered to the Purchasing Department physical dropbox/mailbox, also located in the lobby of City Hall.

B) CLARIFICATIONS FROM REQUESTS FOR INFORMATION:

QUESTION 1: Detail 2/D1 calls 3" minimum temp patch depth, Spec book sec 320.01 states 2" minimum. Please advise.

ANSWER 1: ALL temporary patch shall be 2-inches in depth, minimum.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME	Dan Marran, C.P.M., CPPO Contracts and Risk Manager
XAuthorized Signature	December 12, 2022
Printed Name of Person Signing	