



ADDENDUM #1
FIRE STATION PAGING SYSTEM INSTALLATION
BID # 22/23-036 / PWP # WA-2023-358
BIDS DUE NO LATER THAN: 1:45 PM ON MAY 18, 2023
PUBLIC BID OPENING: 2:00 PM ON MAY 18, 2023

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

A) Bid Document Delivery – Due to hybrid schedules and staff reductions, in-person staff availability is limited. Bidders wishing to physically deliver their bids on the bid due date shall note that the Purchasing Office will receive bids in the lobby of City Hall beginning at 1PM on May 18th. Bids are due no later than 1:45PM. Bids may also be delivered to the Purchasing Department physical dropbox/mailbox, also located in the lobby of City Hall.

B) RFI Questions/Responses:

1. Page 38, Special Provisions, Section 4 state the following: Work shall be completed within 50 calendar days form notice to proceed.

- a. Will City of Sparks contract directly with Purvis for Equipment, programming, integration and commissioning?**
 - i. Sparks is providing the Purvis Equipment. Purvis will be responsible for the programming and integration. The contractor will assist Purvis in the commissioning of the system.*
- b. Installation can not begin until all Purvis equipment is received. Will the 50 Calendar Days include this material delivery period or begin once it is all received?**
 - i. The notice to proceed will not be given until all materials have been received. Once construction starts the contractor will be required to complete the work within 50 calendar days.*
- c. Is the 50 day time frame to include Purvis Equipment arrival, Station Intergration testing, CAD (dispatch) testing, CAD Programing, Fire Staff training, Dispatch training and all demo of old system once the new Purvis system is live? Many of these processes and time frames are owner controlled.**
 - i. Fire Staff Training is not required to be completed in the 50 calendar days.*
- d. Do you have a date when all Purvis equipment will be delivered?**
 - i. Delivery date of the Purvis equipment is still undetermined.*

2. **Page 42, Base Bid Items. Demo of stations 1-5**
 - a. **Blanking off holes in wall and hard ceilings: If the holes in walls and hard ceilings from existing systems are larger than a standard electrical blank plate is the contractor required to repair sheetrock, patching and painting of said larger holes or will this be taken care of by City of Sparks?**
 - i. *All holes larger than a blank plate requiring sheetrock work will be done by others or City.*
3. **Page 54, Purvis FSAS Component table:**
 - a. **Who is providing 120VAC Power for Remote Touch Screen, Turnout Timers, Message Boards And head end equipment? These items are required but not shown on drawings.**
 - i. *The contractor is required to get electrical to these items.*
 - b. **Where are the message Boards located at each station?**
 - i. *Message boards are not required for this project.*
 - c. **Who is providing the message board and mount?**
 - i. *Message boards are not required for this project.*
 - d. **What size is the Dorm Remote Plate?**
 - i. *This is unknown at this time.*
 - e. **Where are the Desktop Mic locations for each station?**
 - i. *Locations will be determined in the field.*
 - f. **Where are the Volume Controls located for each station?**
 - i. *Locations will be determined in the field.*
 - g. **Where are the Multi-Color Tower lights located at station 1?**
 - i. *Locations will be determined in the field.*
 - h. **Where is the 3” Red light located at station 3?**
 - i. *Locations will be determined in the field.*
 - i. **Station 1 calls for (4) wall mount strobe lights but only (2) shown on the drawings, where are the other (2) strobe lights located?**
 - i. *At this time assume there are 4 wall mount strobe lights. Locations will be determined in the field.*

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

 CONTRACTOR BUSINESS NAME

 Dan Marran, C.P.M., CPPO
 Contracts and Risk Manager

X _____
 Authorized Signature

May 12, 2023

 Printed Name of Person Signing