



**ADDENDUM #1**

**2024 CDBG PHASE 2 PROJECT – E ST, F ST, AND 12<sup>TH</sup> ST – FEDERALLY FUNDED**

**BID # 23/24-017 / PWP # WA-2024-242**

**BIDS DUE NO LATER THAN: 1:45 PM ON MARCH 27, 2024**

**PUBLIC BID OPENING: 2:00 PM ON MARCH 27, 2024**

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

- A) **Plantmix Bituminous Pavement** – There is a discrepancy between the project specifications and details. For clarification, plantmix bituminous pavement PG64-22, Type 3 aggregate, 50 Blow, 3% air voids with lime per NDOT Marination Method shall be used for all asphalt hot mix for this project.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications, or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

\_\_\_\_\_  
CONTRACTOR BUSINESS NAME

\_\_\_\_\_  
Amber Sosa, P.E.  
Transportation Manager

X \_\_\_\_\_  
Authorized Signature

March 13, 2024

\_\_\_\_\_  
Printed Name of Person Signing