



**ADDENDUM #1
SAND FILTRATION PROJECT
BID #13/14-020
BIDS DUE NO LATER THAN: 1:45 PM ON MARCH 25, 2014
PUBLIC BID OPENING: 2:00 PM ON MARCH 25, 2014**

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

GENERAL

In all areas requiring the installation of new filter media (sand, anthracite or gravel) or filter heads, the contractor is also required to procure and supply those materials. This would apply in all instances in the bid document that describe the "installation of new" materials.

REQUESTS FOR INFORMATION

The City has received some questions from interested contractors. Those questions and responses are detailed below:

1) Is the contractor responsible for the disposal cost or is the disposal for TMWRF and the contractor does the transport?

CITY RESPONSE: *The Contractor is responsible for all transportation and disposal logistics and costs where required.*

2) Is TMWRF providing the filtration material for the filters or is the contractor responsible for the purchase of the materials?

CITY RESPONSE: *The Contractor is responsible for the purchase of all materials required for the project including any required filtration media placed at the site.*

3) Is TMWRF also providing the replacement filter heads?

CITY RESPONSE: *The Contractor is responsible for the purchase of all materials required for the project including the required filter heads.*

4) Is this a prevailing wage project? Or will this be a maintenance contract?

CITY RESPONSE: *The project under bid is a maintenance project and therefore does not meet the definition of a public work under NRS 338. Therefore, the payment of prevailing wage is not required.*

5) The bid is to only reflect the labor, tools, and equipment for the removal and replacement of the media?

CITY RESPONSE: *Please refer to the detail in the bid documents. Generally speaking the project requires the addition of filter media to existing media. Requirements are detailed in the bid book and*

associated drawings. Quantities of material removal and additions are found in the drawings (Sheet 4).

6) Will any of the existing media be cleaned and reused by the contractor or will all media be replaced?

CITY RESPONSE: *Please refer to the detail in the bid documents. Generally speaking the project requires the addition of filter media to existing media. Requirements are detailed in the bid book and associated drawings. Quantities of material removal and additions are found in the drawings (Sheet 4).*

7) What type of testing (analytical) will be required?

CITY RESPONSE: *Please refer to the detail in the bid documents. The testing requirements are defined on Page 42 of the bid book (Section 3.03 Performance Testing)*

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal (not later than 1:45 pm on March 25, 2014). Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X _____
Authorized Signature

March 14, 2014

Printed Name of Person Signing