



ADDENDUM #2

ROCK PARK RESTROOM

BID #15/16-005 – PWP# WA-2015-255

BIDS DUE NO LATER THAN: 1:45 PM ON AUGUST 26, 2015

PUBLIC BID OPENING: 2:00 PM ON AUGUST 26, 2015

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

A. Drawings

<u>SHEET</u>	<u>DESCRIPTION</u>
E002	The main breaker in Panel LA shall contain a shunt trip coil for connection to the exterior shunt trip station.
E101	Contractor shall provide a minimum of four (4) N-36 (with extensions) in-grade pull boxes between the meter pedestal and the new restroom building. Two (2) pull boxes shall be for power and two (2) for communication.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #2, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 2 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal (not later than 1:45 pm on August 26, 2015). Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X _____
Authorized Signature

August 21, 2015

Printed Name of Person Signing