



ADDENDUM #2

MARINA PUMP STATION REHABILITATION

BID #16/17-013 / PWP # WA-2017-104

BIDS DUE NO LATER THAN: 1:45 PM ON MARCH 8, 2017

PUBLIC BID OPENING: 2:00 PM ON MARCH 8, 2017

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

Pumps

Sheet E-3, "Pump Specifications," Note 6, add: "Impeller material may be cast iron, bronze, stainless steel or approved equal."

Sheet E-3, "Pump Specifications," Note 6, add: "The interior and exterior of the pump discharge head, bowl assembly, and column shall be epoxy coated."

Schedule

Within the "Special Provisions" section of the bid document (Page 35) Section 3 – "Working Days" - Replace Paragraph 2 with:

"Pump Downtime: a period not to exceed sixty (60) calendar days shall be provided to discontinue operations of the existing pumps and begin operations with the new pumps. Liquidated damages, as outlined in Section 4, will be assessed if pumping operations are suspended for a period greater than sixty (60) calendar days."

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #2, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 2 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X _____
Authorized Signature

March 2, 2017

Printed Name of Person Signing