



ADDENDUM #1

FIRE STATION 4 PARKING LOT REHABILITATION

BID #16/17-017 / PWP #WA-2017-142

BIDS DUE NO LATER THAN: 1:45 PM ON APRIL 5, 2017

PUBLIC BID OPENING: 2:00 PM ON APRIL 5, 2017

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

Technical Specifications - Changes/Clarification

The original language found in Section 314.01.01 (Page 51 of the Bid Document) shall be deleted and replaced with the following:

314.01.01 Composition of Mixtures. Concrete shall be Type II Portland Cement which shall be a 650 psi flexural strength concrete mix design. Structural Fibers-reinforcing, Tuf-Strand SF or approved equal, shall be added to mix at 2 ½ to 4 pounds per cubic yard of concrete, or per manufacturers recommendation on approved equal.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

X _____
Authorized Signature

Printed Name of Person Signing

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

April 3, 2017