



ADDENDUM #3

VICTORIAN SQUARE INFRASTRUCTURE

BID #17/18-008 / PWP #WA-2018-010

BIDS DUE NO LATER THAN: 1:45 PM ON OCTOBER 18, 2017

PUBLIC BID OPENING: 2:00 PM ON OCTOBER 18, 2017

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

REVISIONS:

PAVER SPECIFICATIONS:

- 1) Page 62-Part 2 Products, 2.1 Materials, Item C Joint Filler:
 - a. Delete current Joint Filler specification
 - b. Contractor shall use a colored polymeric sand to match paver color for joint filler.
- 2) Page 63-Part 3, 3.2 Preparation-Cement Treated (Stabilized) Base:
 - a. DELETE the entire Section 3.2.
 - b. Contractor shall install pavers, sand, concrete slab, and aggregate base as described in Bid Item Clarification C1 and shown on the detail on Sheet 3.1 on the plans.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #3, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 3 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X _____
Authorized Signature

October 12, 2017

Printed Name of Person Signing