



**ADDENDUM #1
HVAC SYSTEM UPGRADE-SPARKS REC CENTER
BID #19/20-005 / PWP #WA-2020-053
BIDS DUE NO LATER THAN: 1:45 PM ON NOVEMBER 14, 2019
PUBLIC BID OPENING: 2:00 PM ON NOVEMBER 14, 2019**

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

1. HVAC Controls Clarification:
 - a. The Sparks Recreation Center HVAC controls will be a stand-alone system. The system will NOT be tied to the city-wide Alerton HVAC control system.

2. Bid Item Clarification Modification
 - a. The original language found describing Bid Item 2 (Page 42 of the Bid Documents) shall include the following language:
 - i. “This bid item shall include cleaning of the existing supply and return ducting prior to installation of the new duct work.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

X _____
Authorized Signature

November 7, 2019

Printed Name of Person Signing