



**ADDENDUM #3
REGIONAL TRAIL RETAINING WALL REPLACEMENT AND UPGRADES
FEDERALLY FUNDED**

**Bid Number #19/20-006 / PWP# WA-2020-065
FEDERAL PROJECT NUMBER TAP-0031(137)
NDOT PROJECT ID NUMBER 60860**

**BIDS DUE NO LATER THAN: 1:45 PM ON JULY 29, 2020
PUBLIC BID OPENING: 2:00 PM ON JULY 29, 2020**

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

REMINDER TO BIDDERS:

COVID-19 Precautions – Due to the City’s response to the COVID-19 virus and associated reduction in staff, in-person staff availability is limited. Bidders wishing to physically deliver their bids on the bid due date shall note that the Purchasing Office will open at 1PM on July 29th for the purpose of receiving bids. Bids may also be delivered via USPS, UPS, FEDEX at any time prior to the bid deadline. Bids are due no later than 1:45PM on July 29, 2020. The public bid opening will be available to all bidders via Zoom as detailed in the Notice to Bidders. A complete bid recap will be available on the City’s website no later than 5PM on July 29, 2020.

Request for Information (RFI) responses:

A. Revisions to Request for Information (RFI) response #1 on Addendum #2 in reference to change in block size, cap thickness, manufacturer structural pinning and tie back requirements, and minimum bury depth:

1. Revisions to Requested information on the following list of items on Addendum #2:
 - a. Type of Block?
 - i. The masonry block is a structural segmental retaining wall system block either tri-plane or straight face sized at 18” length x 8” tall x 12” depth setback minimum 1” per course with a 4” thick cap on top. Pinning of blocks will be required for wall and height shall not exceed 44” in total height. Wall shall be installed per manufacturers recommendation.
 - b. Color?
 - i. The approved color is Grey.
 - c. Is tie back required?
 - i. Refer to manufacturer’s recommendation.
 - d. Depth of bury of initial block course?

- i. Minimum depth of bury for first course of block is 6” from top of adjacent concrete path. Full depth bury of first course is not required. Depth will vary with slope of adjacent path.

B. Modification to 4” Perforated ADS Pipe:

- a. The 8 oz. needle punched non-woven geotextile wrap is not required for the project.

Please note and adjust your bid according to the revisions, additions, deletions, clarifications or modifications as presented on this Addendum #3, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum 3 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm’s sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

X _____
Authorized Signature

Printed Name of Person Signing

Dan Marran, C.P.M., CPPO
Contracts and Risk Manager

July 24, 2020