



# WOOD RODGERS

March 27, 2019

Mr. Jim Rundle  
Planning Manager  
City of Sparks  
431 Prater Way  
Sparks, Nevada 89431

**Re: Project Parcel Slope Analysis  
High School at Wildcreek**


Dear Jim;

As requested, we have reviewed the project parcel slope analysis. Based upon this analysis, the project is proposing to develop 0.4 acres of land that is at or above 30% slope. Per City of Sparks Development code this is allowed provided the project also sets aside, at a 2:1 ratio, land within other slope categories as undisturbed. In order to comply with this code, the project is setting aside a minimum of 0.8 acres of land within the 0-15% slope category as a mitigation for this requirement.

Should you have any questions or wish to discuss this matter further, please don't hesitate to contact me at this office.

Sincerely,

**WOOD RODGERS, INC.**



Mark Casey, P.E.  
Vice President