



WOOD RODGERS

March 27, 2019

Mr. Jim Rundle
Planning Manager
City of Sparks
431 Prater Way
Sparks, Nevada 89431

**Re: Project Parcel Slope Analysis
High School at Wildcreek**


Dear Jim;

As requested, we have reviewed the project parcel slope analysis. Based upon this analysis, the project is proposing to develop 0.4 acres of land that is at or above 30% slope. Per City of Sparks Development code this is allowed provided the project also sets aside, at a 2:1 ratio, land within other slope categories as undisturbed. In order to comply with this code, the project is setting aside a minimum of 0.8 acres of land within the 0-15% slope category as a mitigation for this requirement.

Should you have any questions or wish to discuss this matter further, please don't hesitate to contact me at this office.

Sincerely,

WOOD RODGERS, INC.



Mark Casey, P.E.
Vice President