



ADDENDUM #1

ALF SORENSEN COMMUNITY CENTER GYM HVAC REPLACEMENT

BID #26/27-001

PWP #WA-2026-486

BIDS DUE NO LATER THAN: 1:45 PM ON SEPTEMBER 2, 2026

PUBLIC BID OPENING: 2:00 PM ON SEPTEMBER 2, 2026

This addendum is to notify all potential proposers of clarifications made to the Bid documents as stated below.

1. Controls contractor to provide and install R454b refrigerant detector and interlock with EF to purge room when refrigerant is detected. The refrigerant detector shall be tied to the existing Alf Sorensen Alerton DDC system to monitor and alarm City of Sparks staff in the event of a refrigerant leak. **This item is for informational purposes only. The City will contract this item separate from the bid.**

Please note and adjust your bid if required according to the revisions, additions, deletions, clarifications, or modifications as presented on this Addendum #1, which are made a part of this bid. NOTE: To avoid disqualification, this Addendum #1 (and any other addenda) must be signed by an authorized representative of the bidding firm in the space provided and must be submitted with your firm's sealed proposal. Failure to return this addendum, duly signed, may be cause for rejection of the bid. ALL ADDENDA SHOULD BE SIGNED AND PLACED IN SEQUENTIAL ORDER AND ATTACHED TO THE FRONT OF THE BID PACKAGE, COMPLETE WITH ALL REQUIRED DOCUMENTS.

CONTRACTOR BUSINESS NAME

X _____
Authorized Signature

Printed Name of Person Signing

Brian Cason

Brian D. Cason, S.E., P.E.
Capital Projects Manager

August 28, 2026